



# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

**Applicant:** KLH Massivholz GmbH  
 Gewerbestraße 4  
 Teufenbach-Katsch A-8842  
 Austria

**Contact:** Johannes Habenbacher

**Phone:** +43 664 548 46 80

**Email:** johannes.habenbacher@klh.at

**Party Authorized to Apply Mark:** See following page(s)

**Evaluation Center:** Evaluation Services (ES)

**Client Number:** 277568

Authorized By:   
 Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.  
 545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA  
 Phone: 847-439-5667 Fax: 847-439-7320



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

<b>Testing Standard(s):</b>	ANSI / APA PRG 320 (2018), ASTM E119 (2019), ASTM E84 (2018b), ICC-ES AC455 (2021), ANSI / APA PRG 320 (2019)
<b>Product:</b>	KLH Massivholz GmbH – Massivholzplatten (solid wood slabs) CLT

**ATM for Report:** G102232156, G103136174, G103855227,  
 G104162725, G104769676

**ATM Issue Date:** 1/28/2025

**Listing Section(s):** BUILDING PANELS

**CSI Code(s):** 06 17 19 Cross-Laminated Timber

**Description:**

KLH-Massivholzplatten (solid wood slabs) cross laminated timber (CLT) is a wood structural building element for walls, floors (ceilings) and roofs. The CLT panels consist of 3 to 8 layers of Austrian Spruce lumber boards stacked crosswise (layers at 90°) and glued on their wide faces. Some panel layups include two adjacent surface layers and/or two adjacent central layers that are arranged parallel to each other. The CLT panels are offered in a maximum length of 54 ft 2 in. (16.5 m); widths of 7 ft 10 in. (2.40m), 8 ft 2 in. (2.50m), 8 ft 11 in. (2.73m) and 9 ft 8 in. (2.95 m); maximum thickness of 1 ft 1/2 in. (0.32 m).

**CODE COMPLIANCE RESEARCH REPORT**

Evaluation Method	Building Code	CCRR Number
ICC-ES AC455	2024, 2021 and 2018 IBC 2024, 2021 and 2018 IRC 2022 California Building Code	CCRR-0434

**FLAME SPREAD RATINGS**

Test Standard	Flame Spread Index	Smoke Developed Index
ASTM E84	75 or less	450 or less

**ASTM E119 FIRE RATINGS**

Panel Layup	Restricted Load Condition	Duration Rating	CCRR Number
130 5s TL (Roof) <sup>1</sup>	27% of Max Load Condition	60 min w/ hose	CCRR-0434
160 5s TL (Floor)	71% of Max Load Condition	60 min w/ hose	CCRR-0434
175 5s TL (Floor)	36% of Max Load Condition	120 min w/hose	CCRR-0434
175 5s TL (Wall)	12% of Max Load Condition	120 min w/hose	CCRR-0434
180 5s TL (Floor)	53% of Max Load Condition	120 min w/hose	CCRR-0434

<sup>1</sup>See CCRR-0434 for details of roof assembly.

**MATERIAL RATINGS**

Test Standard	Test Type	Rating
ANSI/APA PRG 320	Performance Rated CLT	Custom Layup CV3M1

**For Use in the U.S.**

Grade	Laminations in Major Strength Direction (psi)						Laminations in Minor Strength Direction (psi)					
	F <sub>b,0</sub>	E <sub>0</sub> (10 <sup>6</sup> )	F <sub>t,0</sub>	F <sub>c,0</sub>	F <sub>v,0</sub>	F <sub>s,0</sub>	F <sub>b,90</sub>	E <sub>90</sub> (10 <sup>6</sup> )	F <sub>t,90</sub>	F <sub>c,90</sub>	F <sub>v,90</sub>	F <sub>s,90</sub>
CV3M1	975	1.6	550	1,450	175	55	975	1.6	550	1,450	175	55

Tabulated values are allowable design values and not permitted to be increased for the lumber size adjustment factor in accordance with the NDS. The design values shall be used in conjunction with the section properties provided by KLH based on the actual layup used in manufacturing the CLT panel.

**For Use in Canada**

Grade	Laminations in Major Strength Direction (MPa)						Laminations in Minor Strength Direction (MPa)					
	F <sub>b,0</sub>	E <sub>0</sub>	F <sub>t,0</sub>	F <sub>c,0</sub>	F <sub>v,0</sub>	F <sub>s,0</sub>	F <sub>b,90</sub>	E <sub>90</sub>	F <sub>t,90</sub>	F <sub>c,90</sub>	F <sub>v,90</sub>	F <sub>s,90</sub>
CV3M1	10.8	11,000	5.5	15.0	1.8	0.60	10.8	11,000	5.5	15.0	1.8	0.60

Tabulated values are Limit States design values and not permitted to be increased for the lumber size adjustment factor in accordance with the CSA O86. The design values shall be used in conjunction with the section properties provided by KLH based on the actual layup used in manufacturing the CLT panel.

**Party(s) Authorized by Manufacturer To Apply Mark:**

KLH Massivholz GmbH

Gewerbestraße 4

Teufenbach-Katsch A-8842

Austria

Contact: Johannes Habenbacher

Phone: +43 664 548 46 80

Email: johannes.habenbacher@klh.at

**Party(s) Authorized by Other Parties To Apply Mark:**

None